

Trade Mark	Equation					
Model	100 Simple K Q1					
Specific energy consumption (SEC), kWh/(m <sup>2</sup> .A)	Cold		Average		Warm	
	-30,1	B	-13,7	E	-4,3	F
Type of ventilation unit	Unidirectional residential ventilation unit					
Type of drive installed	Single speed					
Type of heat recovery system	None					
Thermal efficiency of heat recovery, %	Non applicable					
Maximum flow rate, m <sup>3</sup> /h	72					
Electric power input, W	8					
Sound power level, dB(A)	49					
Reference flow rate, m <sup>3</sup> /s	0,014					
Reference pressure difference, Pa	Not applicable					
Specific power input (SPI), W/(m <sup>3</sup> /h)	0,111					
Control typology	Local demand control					
Maximum internal leakage rates, %	Not applicable					
Maximum external leakage rates, %	2,7%					
Airflow sensitivity at +20 Pa and -20 Pa	0,15					
The indoor/outdoor air tightness, m <sup>3</sup> /h	1					
Internet address	<a href="http://www.erp-equation.com/aerators/">http://www.erp-equation.com/aerators/</a>					
The annual electricity consumption (AEC), kWh electricity/a	Cold		Average		Warm	
	139		139		139	
The annual heating saved (AHS), kWh primary energy/a	Cold		Average		Warm	
	3355		1715		776	